

RESNET® Standards Public Comment and Proposed Change Form

Comment/Explanation*:

Include your justification for your proposed change to the draft standard below.

3. 2 Definitions P. 9 : The definition of gross floor area should be clarified to specify whether "garage area" is included, and whether "enclosed parking" is considered the same as a garage.

Proposed Change to the Draft Standard*

Use "strikethrough" and "underline" formatting to indicate all proposed changes. Changes must be shown with "hard-formatting" strikethrough and underline, not "track changes".

Use a color other than red to indicate proposed changes to the draft.

(if garage area is excluded) :

Gross Floor Area (GFA) – The sum of the floor areas of all enclosed spaces inside the building. Measurements must include walls and be taken from their exterior faces. **Garage area**, enclosed parking and access roads are excluded, as are air shafts, pipe trenches, chimneys, and penthouse spaces with headroom height of less than 2.2 meters (7.5 feet).